
INDEX	AS-958249
REV. LEVEL	2
SHEET	1 OF 1

TOSHIBA/HOUSTON CT EXPLOSION PROOF MOTORS HORIZONTAL FOOT-MOUNTED

Fr. 143T-145T



UNITS: INCHS

FRAME		MOU	NTIN	3		CONE	UIT E	BOX	
SIZE	Ε	2F	Н	BA	AA	AB	AC	AF	ΑE
143T	2.75	4.00	0.34	2.25	NPT3/4"	8.74	6.85	1.73	4.84
145T	2.75	5.00	0.34	2.25	NPT3/4"	8.74	6.85	1.73	4.84

FRAME			MOTOF	DIMEN	SIONS		
SIZE	Α	В	С	D	G	Р	O+T
143T	6.69	5.12	12.95	3.50	0.35	8.40	9.30
145T	6.69	6.10	13.94	3.50	0.35	8.40	9.30

SIZE	HP	POLE	WEIGHT
143T	1.5HP	2	83 lbs
143T	1HP	4	79 lbs
145T	2HP	2	94 lbs
145T	1.5HP	4	88 lbs
145T	2HP	4	90 lbs
145T	1HP	6	90 lbs

Γ	FRAME	SHAFT EXTENSION				KEY			BEARINGS	
	SIZE	N-W	U	٧	R	WIDTH	THICKNESS	LENGTH	LS	OS
L	143T	2.25	0.875	2.20	0.771	0.188	0.188	1.375	6205ZZ	6205ZZ
	145T	2.25	0.875	2.20	0.771	0.188	0.188	1.375	6205ZZ	6205ZZ

ALL DATA SUBJECT TO CHANGE WITHOUT NOTICE. FOR CONSTRUCTION USE ONLY CERTIFIED DATA.

NOTES:

- DIMENSION V REPRESENTS LENGTH OF STRAIGHT PART OF SHAFT.
- MOTOR WEIGHT SHOWN IS MAXIMUM HORSEPOWER IN FRAME.

CERT	IFIFD	$D\Delta T\Delta$
CERT	ILIED	DATA

CUSTOMER:				
MOTOR MODEL NO.: 0014XPEA3	1А-Р то	SHIBA FILE NO.:		
HP: 1 RPM (SYN.): 1800		_VOLTAGE: _ 230/460	_ нz: 60	
FRAME SIZE: 143T	OG NO.:	LOG REV. LEVEL: _		
REMARKS:				
PER:	ISSUE DATE:	SUPERSEDES:		
			AS-9582	49

TOSHIBA INTERNATIONAL CORPORATION

Industrial Division / Houston Motor Plant

INDEX	MPCF-1033
SHEET NO.	1 of 1
ISSUED	11/08/96
SUPERSEDES	10/06/95
REVISION	1
WRITTEN BY	R. EVANS
APPROVED BY	Jay Bugbee

SQUIRREL CAGE INDUCTION MOTOR PERFORMANCE SPECIFICATIONS

Customer Tag:

CUSTOMER: TIC SR No.: Customer PO:

MOTOR NAMEPLATE DATA					
H.P.: 1	VOLTS: 230/460	3Ø/60	Hz	S. RPM: 1800	
FRAME: 143T	ENCL: TEXP	FLAMPS: 1.4		FLRPM: 1730	
FORM: FBK1XX	S.F.: 1.15	NEMA DESIGN: B		INSUL CLASS: F	
TYPE: IK	AMB.: 40C	CODE: K		DUTY: CONT.	
MODEL No.: 0014XPEA3	1A-P	kW: 0.75		Serial No.:	
NOM. EFF.: 86.5	MIN. EFF.:	P.F.:0.8			

AMPERAGE	TORQUES	** BEARINGS:
Locked Rotor: 11	FULL LOAD (lb-ft.): 3.00 LOCKED ROTOR (%): 290 BREAK DOWN (%): 310	Drive End: 6205ZZ Opposite Drive End: 6205ZZ

EFFICIENCY (%)	POWER FACTOR (%)
FULL LOAD: 86.5	FULL LOAD: 78.0
3/4 LOAD: 86.5	3/4 LOAD: 71.5
1/2 LOAD: 82.5	1/2 LOAD: 58.5

ALL CHARACTERISTICS ARE AVERAGE EXPECTED VALUES BASED UPON RATED VOLTAGE, FREQUENCY AND SINEWAVE POWER INPUT.

* TEMPERATURE RISE WILL BE CONSISTENT WITH INSULATION, AMBIENT AND SERVICE FACTOR AS DEFINED BY NEMA-MG-12.43 OR -20.40.

** BEARINGS ARE THE ONLY RECOMMENDED SPARE PART(S).

CERTIFIED BY: DATE:



Reliability in Motion

TOSHIBA INTERNATIONAL CORPORATION

INDUSTRIAL DIVISION PO BOX 40906 HOUSTON TX 77240 (713) 466-0277

(800) 231-1412 FAX (713) 466-8773

SPARE PARTS (RECOMMENDED)

OTHER THAN THE GREASE USED FOR RE-GREASABLE BEARINGS, TOSHIBA ADVISES THAT THERE ARE NO "USE" PARTS. THE ONLY INSURANCE SPARES THAT TOSHIBA SUGGESTS FOR THESE SQUIRREL CAGE INDUCTION MOTORS ARE INDUSTRY STANDARD, AND COMMERCIALLY AVAILABLE ANTI-FRICTION BEARINGS, AS NOTED BELOW.

MOTOR COMPONENTS (SUCH AS TERMINAL BOXES, FAN COVERS, MACHINED PARTS) ARE AVAILABLE UPON SPECIAL REQUEST. IN THIS CASE, PLEASE ADVISE OUR ORDER ENTRY DEPARTMENT THE MODEL AND SERIAL NUMBERS (FOUND ON THE MOTOR NAMEPLATE), AND A DESCRIPTION OF THE COMPONENT REQUIRED. THEY WILL THEN FURNISH THE CURRENT PART NUMBER, PRICE AND AVAILABILITY.

(NOTE: OUR INTERNAL PART NUMBERS ARE SUBJECT TO CHANGE WITHOUT NOTICE, AND ARE NOT PUBLISHED).

PLEASE ADVISE IF YOU HAVE ANY QUESTIONS.

CUSTOMER:
PURCHASE ORDER #
Customer Tag:

TOSHIBA FILE #

MODEL # 0014XPEA31A-P


HP / RPM / ENCL / FRAME: 1 / 1800 / TEXP / 143T

DRIVE END BEARING: 6205ZZ
OPPOSITE DRIVE END BEARING: 6205ZZ

Prepared By: Date:

TOSHIBA

Three Phase Motor Wiring Diagram "Across the line" (Full Voltage) Starting



Customer Name:	
PO No.:	
Customer Tag:	
TIC File No.:	
Motor Model No.	0014XPEA31A-P

For Further Information Regarding Toshiba motor starting, maintenance or wiring, Please refer to the "Toshiba - A Quality Product for World Energy" Installation and Maintenance Manual, or contact the Toshiba Low Voltage Motor Marketing Department. (800) 231-1412

Prepared By Date: