


SINGLE VOLTAGE – THREE PHASE WITH OVERLOAD PROTECTOR




NOTE:
ACTUAL PROTECTORS
TERMINAL LOCATIONS
FOR LEAD CONNECTIONS

NOTE:

WEST PLAINS

LEADS WITH TERMINALS
SHOULD BE CONNECTED
TO INBOARD SIDE OF
TERMINAL BOARD.



T1 — 4A
T2 — 5A
T3 — 6A } IF
REQUIRED

—TO REVERSE ROTATION—
INTERCHANGE ANY TWO
LINE LEAD CONNECTIONS


VIEW OF TERMINAL END

OPTIONAL CORD
CONNECTION

L1 — WHITE
L2 — RED
L3 — BLACK

		T6CK
T6CA		T6BM
T4CC		T4AY
T4C		T2DL
T6D		T2H

* USE PRESSURE CONNECTORS FOR MT2 PLANT ONLY

11	ADDED THE OPTIONAL CORD CONNECTION	JAH 11-12-2014	RD	TOLERANCES UNLESS SPECIFIED		 MARATHON ELECTRIC	DRAWN KL 08-25-1993			
10	PRESSURE CONNECTORS ADDED (QTY 3)	PVR 07-09-2014	GR	DEC.	INCHES		CHK	RD 11-12-2014		
9	ADDED 4A, 5A, & 6A "IF REQUIRED" MU44987	MSG 01-07-2002	SAS	.X	± -		APPD	RD 11-12-2014		
8	ADDED ACTUAL PROTECTOR VIEW CN 17481	KL 05-18-1994		.XX	± -		SCALE	1=1		
7	REWORDED WEST PLAINS NOTE – PER WEST PLAINS	DD 01-12-1994		.XXX	± -	TITLE CONNECTION DIAGRAM SINGLE VOLT – 3Ø WITH OVERLOAD PROT.		REF		
6	REDRAWN ON CAD – "WEST PLAINS" NOTE ADDED	KL 08-26-1993		.XXXX	± -	MAT'L.		FMF		
NO.	REVISION	BY & DATE	CHK	ANG	± -	FINISH		PREV		
THIS DRAWING IN DESIGN AND DETAIL IS OUR PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH OUR WORK ALL RIGHTS OF DESIGN AND INVENTION ARE RESERVED THIS IS AN ELECTRONICALLY GENERATED DOCUMENT – DO NOT SCALE THIS PRINT			RFP		CAD FILE EE7335B		SIZE A	DRAWING NO. EE7335B	PAGE OF	REV. 10
			DIST LB-WP							